

Optimal LQ-controller Design and Data Drop Distribution under (m,k) -firm constraint

Ning Jia, Ye-Qiong Song, Françoise Simonot-Lion

► **To cite this version:**

Ning Jia, Ye-Qiong Song, Françoise Simonot-Lion. Optimal LQ-controller Design and Data Drop Distribution under (m,k) -firm constraint. workshop on advanced control and diagnosis 2006, Nov 2006, nancy, france, 2006. <inria-00113830>

HAL Id: inria-00113830

<https://hal.inria.fr/inria-00113830>

Submitted on 14 Nov 2006

HAL is a multi-disciplinary open access archive for the deposit and dissemination of scientific research documents, whether they are published or not. The documents may come from teaching and research institutions in France or abroad, or from public or private research centers.

L'archive ouverte pluridisciplinaire **HAL**, est destinée au dépôt et à la diffusion de documents scientifiques de niveau recherche, publiés ou non, émanant des établissements d'enseignement et de recherche français ou étrangers, des laboratoires publics ou privés.

Optimal LQ-controller Design and Data Drop Distribution under (m,k) -firm constraint

Jia Ning, Song YeQiong, Simonot-Lion Françoise

LORIA – INPL
Campus Scientifique – BP 239
54506 – Vandoeuvre lès Nancy France
{Ning,Jia,song,simonot}@loria.fr

Abstract

The share of the network link in a networked control system (NCS) may result in the network overload where the periodicity of control system could be infected, causing an unpredictable performance degradation in control system. In this paper, we consider an overload management technique which selectively drops the data packets of the NCS to avoid the network overload. The problems investigated are: how to design the controller under packet drops and how to distribute the packet drops in a packet delivery sequence so that the quality of control (QoC) is optimized. The paper first gives the optimal LQ-controller by using the conventional technique to reduce the deterioration in QoC due to packet drops. Then, the paper proposes a methodology for deriving the distribution of the packet drops in the packet delivery sequence so that the QoC is optimal. To reduce the computation complexity of the proposed methodology, a computationally cheaper algorithm is also given. This proposal contributes to the co-design of the controller and the resource performance management process at the implementation level.

1. Introduction

In this paper, we consider an NCS (see figure 1). The sensor and the controlled are linked by the network link. The output of the process is sampled periodically and the process state variables are transmitted in a packet to the controller over the network link. The transmission of the packet over the network link introduces a delay between the sampling instant and the control law completion. If this delay is constant, the value of this delay can be easily taken into account for the design of the control law. Nevertheless, the constant-delay assumption cannot be guaranteed if the network is a resource shared by several applications especially due to network overload period. The network over load must be handled since the time varying network-induced delay can degrade the QoC and can even destabilize the system.




Figure 1. Control system model

One way to avoid the network overload is to enlarge the sampling periods of control system [3][4][15]. However, changing the sampling period of a control system alters its dynamics. Another approach is to selectively drop the packets to reduce the network charge. The solution discussed in this paper for dealing with the network overload is based on this latter approach.

More specifically, our solution to handle the network overload is based on the (m,k) -firm constraint model [8][14]. The (m,k) -firm constraint requires that at least m packets among any k consecutive packet sent from the sensor must be received by the controller, where m and k are two positive integers with $m \leq k$ (the case where $m=k$ is equivalent to the ideal case, which is noted by (k,k) -firm). Obviously, the packet drops tend to degrade the QoC due to the misses of control law updates. However, if a control system is designed to accept a degradation of QoC until $k-m$ packet drops among k consecutive packet (this can be justified by the observation that most control systems can tolerate misses of the control law updates to a certain extent), the system can then be conceived according to the (m,k) -firm approach to offer the varied levels of QoC (between (k,k) -firm (ideal case) and (m,k) -firm (worse case)) with as many intermediate levels as the possible values between k and m . Which results in a control system with graceful degradation of QoC.

The application of such an overload management strategy in control system requires a systematic study of the impact of the packet drops based on the (m,k) -firm constraint on the QoC. However, in most of the prior

approaches, like those in [11][12][16], the packet drop process is regarded as an indeterminist process, therefore only some statistical results have been produced. An important contribution is found in [14]. In this work, the author proposed a scheduling technique based on the (m,k) -firm constraint that discards selectively the control law computation to handle the overload in processor, and the author also proposed a methodology for modifying the control law to reduce the deterioration in QoC due to the misses of control law update. However, the issue that how to choose a reasonable (m,k) -firm constraint that guarantees control system stability wasn't addressed, and the proposed algorithm implicitly discards the control law computation without justifying the optimality of the resulted control law update sequence from the QoC point of view. Furthermore, the methodology proposed to derive the optimal control law under control law update misses isn't suitable because the control signal and the process state at the moment when the control law update is dropped aren't penalized in the cost function.

In [9], we presented a formal analysis that derived, for a one-dimensional control system, the m and k values that guarantees the control system stability. We also proposed an approach for deriving the optimal controller under (m,k) -firm constraint. In [6], we extended the work in [9] to a multiple dimension control system. We showed how to determine the value of k that preserves the stability of the system and how to identify the values of m in order to minimize the LQR (linear quadratic regulator) cost. After having shown the distribution of the packet drops in a packet delivery sequence has an important impact on the QoC, we justified that, for the finite time horizon, a judicious choose of packet delivery sequence plays a important role in reducing the degradation in QoC. In this paper, we propose a general method to derive the optimal LQ-controller under (m,k) -firm constraint by using the conventional technique. We also present a methodology to derive, for infinite time horizon, the optimal packet delivery sequence from the QoC point of view.

The paper is organized as follows. In section 2, we formalize the system under study. Section 3 gives the optimal LQ controller under (m,k) -firm constraint. Section 4 presents fundamental considerations concerning the derivation of the optimal packet delivery sequence. A case study of the proposed approach is presented in section 5. Finally, we summarize our work and show the perspectives.

2. Control system description

The control system considered in this work is shown in figure 2. The system consists of a continuous plant:

$$dx = Axdt + Budt + dv_c \quad (1)$$

and a discrete linear controller

$$u_{ih} = -Lx_{ih} \quad i = 0, 1, 2, \dots$$

where $x \in R^n, u \in R^m$, and A, B, L are matrices of appropriate sizes. x is the state vector containing state variables of the controlled process, and u is the control input. The process v_c has mean value of zero and uncorrelated increments. The incremental covariance of v_c is $R_{lc}dt$.




Figure 2. Control system model

We consider the system setup with a) clock-driven sensors that periodically lump the process state variables together into one packet with a period h and send it to the controller b) an event-driven controller that starts the control law calculation as soon as the data packet containing system state sample arrives; and c) event-driven actuators, which means that the process inputs are held until a new control command is available.

The packets containing the process state variables are dropped selectively according to an (m,k) -firm constraint during the network overload period. For analyzing the impact of the (m,k) -constraint on the performance of control system, we placed our selves in the worst-case by assuming a long network overload period and the packet drop process drops systematically $k-m$ packets every k . The packet delivery sequence thus is periodic with period k , i.e., if the n^{th} packet is dropped, the $(n+k)^{\text{th}}$ packet will be also dropped; otherwise, if the n^{th} packet is received by the controller, the $(n+k)^{\text{th}}$ packet will be also received.

With the system setup described above, the discrete time-variant system model of the system (1) for a given packet delivery sequence is given as follows:

$$x_{i+1} = \Phi_i x_i + \Gamma_i u_i + v_i \quad i = 0, 1, 2, \dots \quad (2)$$

where

$$\Phi_i = e^{A_i f_i h}$$

$$\Gamma_i = \int_0^{f_i h} e^{A_i s} ds B$$

and f_i is the number of the consecutively dropped packets plus one. In another word, it gives the distance, in terms of the number of the period h , the distance between any two consecutive control law updates. v_i is a discrete-time Gaussian white-noise process with zero mean value and has the following property:

$$E v_i v_i^T = R_{vi} = \int_0^{f_i h} e^{A_i \tau} R_{lc} e^{A_i^T \tau} d\tau$$

Since the packets are dropped periodically according to a (m,k) -firm constraint, therefore we have $f_i + f_{i+1} + \dots + f_{i+m-1} = k$ and $f_i = f_{i+m}$. Hence, $\Phi_i = \Phi_{i+m}$, $\Gamma_i = \Gamma_{i+m}$, and the system in (2) is periodic with period m .

3. Optimal control law under (m,k) -firm constraint

In this section, the optimal LQ controller is derived for the system (2).

We consider a continuous-time cost function:

$$J = E \left(\int_0^{Nh} x^T(t) Q x(t) + u^T(t) R u(t) \right) + E \left(x^T(Nh) Q_0 x(Nh) \right) \quad (3)$$

where N is a integer that can be exactly divided by k .

The cost function discretized for the discrete LQ controller of the system (2) is given by [7] as:

$$J = \sum_{i=0}^{\frac{mN}{k}-1} \left(x_i^T Q_i x_i + 2x_i^T M_i u_i + u_i^T R_i u_i \right) + E \left(x_{\frac{mN}{k}}^T Q_0 x_{\frac{mN}{k}} \right) + \sum_{i=0}^{\frac{mN}{k}-1} \bar{J}_i \quad (4)$$

where

$$Q_i = \int_0^{f_i h} \Phi^T(t) Q \Phi(t) dt \quad M_i = \int_0^{f_i h} \Phi^T(t) Q \Gamma(t) dt$$

$$R_i = \int_0^{f_i h} (\Gamma^T(t) Q \Gamma(t) + R) dt \quad \bar{J}_i = \text{tr} \left(Q \int_0^{f_i h} R_i(\tau) d\tau \right)$$

and $\Phi(t) = e^{At}$ and $\Gamma(t) = \int_0^t e^{As} ds \cdot B$.

The optimal control law that minimizes the cost function (4) is given by [1] as:

$$u_i = -L_i x_i \quad i = 0, 1, 2, \dots \quad (5)$$

where

$$L_i = \left(\Gamma_i^T S_{i+1} \Gamma_i + R_i \right)^{-1} \left(\Gamma_i^T S_{i+1} \Phi_i + M_i^T \right) \quad (6)$$

and S_i is obtained from the following recursive equation:

$$S_{\frac{mN}{k}} = Q_0$$

$$S_i = \Phi_i^T S_{i+1} \Phi_i + Q_i - \left(\Gamma_i^T S_{i+1} \Phi_i + M_i^T \right)^T \left(\Gamma_i^T S_{i+1} \Gamma_i + R_i \right)^{-1} \left(\Gamma_i^T S_{i+1} \Phi_i + M_i^T \right) \quad (7)$$

Because of the periodicity of Φ_i and Γ_i , the solution of the Riccati equation (5) is also periodic with period k [2].

That is, if the horizon $\frac{mN}{k}$ is large, $S_i = S_{i+m}$. As a result, the solution of the equation (6) is also periodic with period m :

$$L_i = L_{i+m}$$

4. Optimal packet delivery sequence

In this section, we propose a formal methodology to derive the optimal packet delivery sequence that minimizes the cost function (4). Note that finding the optimal packet delivery sequence is to find the suitable values of f_i for $i \in [0, m-1]$ because of the periodicity of packet drops. We first give the derivative of LQ cost function (4) with respect to f_i . This function is then used for deriving the optimal packet delivery sequence

4.1. Derivative of LQ cost function

The minimal value of J given by the optimal LQ controller (5) is derived by [7] as:

$$J = m_0^T S_0 m_0 + \text{tr} S_0 R_0 + \sum_{i=0}^{\frac{mN}{k}-1} \text{tr} S_{i+1} R_{V_i} + \sum_{i=0}^{\frac{mN}{k}-1} \bar{J}_i \quad (8)$$

where

$$\bar{J}_i = \text{tr} \left(Q \int_0^{f_i h} R_i(\tau) d\tau \right) \quad (9)$$

with

$$R_{V_i} = E v_i v_i^T = \int_0^{f_i h} e^{A\tau} R_i e^{A^T \tau} d\tau \quad (10)$$

When time goes to infinity, i.e. $\lim_{m \rightarrow \infty} \frac{N}{k} \rightarrow \infty$, the influence from the initial condition decreases and because of the periodicity of the system, the cost function may be written as

$$J = \sum_{i=0}^{m-1} \text{tr} S_{i+1} R_{V_i} + \sum_{i=0}^{m-1} \bar{J}_i \quad (11)$$

This means that only the stationary cost is regarded and that the cost is scaled by the period of packet delivery sequence k .

In order to use the cost function (11) in the optimization, it is useful to know the derivative with respect to f_i for $i \in [0, m-1]$.

Theorem 1. Given a packet delivery sequence, i.e., $f_0, f_1 \dots f_{m-1}$, the first derivative of J with respect to f_i for $i \in [0, m-1]$ is given as

$$\frac{dJ}{df_i} = \sum_{j=0}^{m-1} \text{tr} \frac{dS_{j+1}}{df_i} R_{V_j} + \text{tr} S_{i+1} \frac{dR_{V_i}}{df_i} + \frac{d\bar{J}_i}{df_i}$$

where $\frac{dS_{j+1}}{df_i}$ is obtained from the following recursive equation:

$$\frac{dS_j}{df_i} = \left(\Phi_{j+1} - \Gamma_{j+1} L_{j+1} \right)^T \frac{dS_{j+1}}{df_i} \left(\Phi_{j+1} - \Gamma_{j+1} L_{j+1} \right)$$

$$\text{for } \text{mod} \left(\frac{j}{m} \right) \neq i$$

and

$$\frac{dS_i}{df_i} = (\Phi_{i+1} - \Gamma_{i+1}L_{i+1})^T \frac{dS_{i+1}}{df_i} (\Phi_{i+1} - \Gamma_{i+1}L_{i+1}) + W_i$$

with

$$\begin{aligned} W_i &= h \left[(\Phi_i - \Gamma_i L_i)^T \quad -L_i^T \right] \begin{bmatrix} Q & 0 \\ 0 & R \end{bmatrix} \begin{bmatrix} \Phi_i - \Gamma_i L_i \\ -L_i \end{bmatrix} \\ &+ \left(h(\Phi_i - \Gamma_i L_i)^T A^T - hL_i^T B^T \right) S_{i+1} (\Phi_i - \Gamma_i L_i) \\ &+ (\Phi_i - \Gamma_i L_i)^T S_{i+1} (hA(\Phi_i - \Gamma_i L_i) - hBL_i) \end{aligned}$$

The matrix R_{vj} can be calculated using lemma 1 in [5] and the derivatives of R_{vj} and \bar{J}_i are obtained directly from Eq (9) and (10).

$$\begin{aligned} \frac{dR_{vj}}{df_i} &= h e^{A f_i} R_{1c} e^{A^T f_i} d\tau \\ \frac{d\bar{J}_i}{df_i} &= tr(QR_{vj}h) \end{aligned}$$

□

See Appendix A for the proof.

4.2 Finding an optimal packet delivery sequence

By optimizing over f_i for $i \in [0, m-1]$ with respect to the cost function (11), the following optimization problem is posed:

$$\begin{aligned} &\text{minimize} \quad J \\ &\text{Subject to} \quad \sum_{i=0}^{m-1} f_i = k \\ &f_i \geq 0 \quad \text{and be integer for } i=0,1,..,m-1 \end{aligned} \quad (12)$$

This optimization problem containing restriction is known as nonlinear integer program. To resolve this problem, the general branch-and-bound algorithm [10] can be used.

According to the branch-and-bound algorithm, the original problem (12) is firstly solved as a continuous nonlinear program ignoring the integrality requirement. If each variable f_i takes integer value, the calculation process is stopped. Otherwise, if the a solution f_i is not completely integer-feasible, then the approach is to generate two new subproblems from (12), with additional bounds, respectively

$$f_i = \lfloor f_i \rfloor$$

and

$$f_i = \lceil f_i \rceil$$

The subproblems are then resolved by ignoring the integrality requirement. If the solution of a subproblem gives a worse cost than the solution of the other subproblem, i.e., the cost obtained is greater than the other, then the solution giving the worse cost is deleted and the above procedure is repeated for the better

solution. The whole process terminates when f_i is integer for $i \in [0, m-1]$.

To solve the continuous nonlinear problem, a powerful technique is to use Kuck-Tucker conditions. For our optimization problem, the Kuhn-Tucker condition gives that if $\{f_0, f_2, \dots, f_{m-1}\}$ is an optimal solution then

$$\begin{aligned} &\left[\frac{dJ}{df_0} \quad \dots \quad \frac{dJ}{df_{m-1}} \right]^T - \Lambda = 0 \\ &f_0 + f_1 + \dots + f_{m-1} - k = 0 \end{aligned} \quad (13)$$

where Λ is a vector of dimension m , in which each element is the Lagrange multiplier λ .

4.3 An approximate version

The methodology proposed above includes solving both Riccati and Lyapunov equations. This is expensive and prevents the implementation of a on-line network charge gestion mechanism that dynamically adjusts the (m, k) -firm constraint and the corresponding packet delivery sequence according to the network charge. Therefore a computationally cheaper algorithm for finding the optimal packet delivery sequence is desirable.

From the Kuhn-Tucker condition (13), we know that the QoC is optimal when $f_0 = f_1 = \dots = f_{m-1}$ (The ideal case, i.e. the distribution of packet drops in a packet delivery sequence is absolutely uniform. However, this isn't always possible since the number of the packets consecutively dropped should be a integer), and one can easily find that the distribution of the packet drops derived by the algorithm proposed is an approximate version of the ideal case. Thus, if the packet drops are distributed as uniformly as possible, we can obtained a sub-optimal QoC or even a optimal QoC in the best case.

To facilitate the presentation of the packet delivery sequence, we will use a binary word of length k on a alphabet composed by 1 and 0. 1 represents that a packet is received by the controller, and 0 represents a packet drop. For example, the binary word 1001000 represents that the first and the fourth packets in a period of packet delivery sequence are received by the controller, all the other packets are dropped. This corresponds to $f_1=3, f_2=4$. We call this binary word the (m, k) -pattern. Therefore, distributing the packet drops as uniformly as possible is to have a (m, k) -pattern in which the letters 0 are uniformly distributed.

From [13], we know that the letters 0 are uniformly distributed in a binary word called upper mechanical word. Therefore, the technique for obtaining an upper mechanical word can be used to derive the (m, k) -pattern. The definition of the upper mechanical word is given as follows:

Definition 1 [13]. A binary word is a upper mechanical if and only if there exist a real number α such that the n^{th} letter of the word is given by

$$\lceil (n+1) \cdot \alpha \rceil - \lceil n \cdot \alpha \rceil \quad \forall n \geq 0. \quad (14)$$

The proportion of the letters 1 and 0 in the upper mechanical word is given by α . For satisfying the requirement for (m,k) -firm constraint, it is enough to replace α by m/k . We thus get, for a (m,k) -firm constraint, the correspond (m,k) -pattern which n^{th} letter is given by

$$\left\lceil (n+1) \cdot \frac{m}{k} \right\rceil - \left\lceil n \cdot \frac{m}{k} \right\rceil \quad \forall n \geq 0. \quad (15)$$

Example 1. Given a (7,10)-firm constraint, from (15), we get the (7,10)-pattern 1110110110.

Using this approximate solution instead of the exact one gives a much less computation density. However, the approximation doesn't represent lower efficiency. We will see in the following section that for our experiment platform, the approximate solution gives the exact optimal solution.

5. Case study

In this section, we present a numerical example to illustrate the derivation of the optimal packet delivery sequence.

Consider a cart-control system whose objective is controlling the position of a cart along a rail according to a position reference. The stats of the cart (speed and position) are periodically sampled and put in a packet which is then sent to the controller over the network link. For avoiding the network overload, the packets are dropped according to a (m,k) -firm constraint.

The continuous model of the cart system is given by:

$$dx = \begin{bmatrix} 0 & 1 \\ 0 & -12.6559 \end{bmatrix} xdt + \begin{bmatrix} 0 \\ 1.9243 \end{bmatrix} udt + dv_c$$

v_c is the disturbance on the control signal with the incremental covariance $R_{lc} = \begin{bmatrix} 0 & 0 \\ 0 & 1^{-5} \end{bmatrix}$.

The continuous-time signal x is sampled with a period of 0.01 second. The packets containing the process samples are dropped according to a (3,11)-firm constraint. The problem of finding the optimal packet delivery sequence is set up as follows:

$$\begin{aligned} & \text{Minimize} && J \\ & \text{Subject to} && \sum_{i=0}^2 f_i = 11 \\ & && f_i \geq 0 \quad \text{and be integer for } i=0,1,2. \end{aligned} \quad (16)$$

According to the algorithm proposed in the previous section, the problem (16) is solved as a continuous nonlinear program ignoring the integrality requirement. From the Kuck-Tucker conditions (13), optimal solution

for the continuous nonlinear program is $f_0=f_1=f_2=3.67$. As this is not an integer solution, we thus force f_0 to be integer. To do so, we branch on f_0 , creating two new sub-problems. In one, we add the constraint $f_0=3$. In the other, we add the constraint $f_0=4$. This is illustrated in figure 3.




Figure 3. First branching

Now, any optimal solution to the overall problem must be feasible to one of the subproblems. By solving the two subproblems with the Kuck-Tucker conditions, we get the following solutions:

$$f_0=3, \quad f_1=4.15, \quad f_2=3.85: J = 0.00103$$

$$f_0=4, \quad f_1=3.35, \quad f_2=3.65: J = 0.0011$$

As the cost obtained with $f_0=4$ is more than that obtained with $f_0=3$, we thus choose $f_0=3$ and branch on f_1 . After solving the resulting subproblems, we have the branch and bound tree in Figure 4.




Figure 4. Second branching

The solutions are:

$$f_0=3, \quad f_1=3, \quad f_2=5: J = 0.0012$$

$$f_0=3, \quad f_1=4, \quad f_2=4: J = 0.0011$$

The best integer solution is given by $f_0=3, f_1=4$ and $f_2=4$. The calculation process terminates since all the variables have taken an integer solution. Note that the solution derived by (15) is, in term of (m,k) -pattern, 10010001000 which is exactly the same with the optimal solution.

To evaluate the benefit of the proposed methodology, for a position reference of 0.1 meter, the position traces of the cart obtained with an arbitrary packet delivery sequence and the optimal packet delivery sequence are respectively given in figure 5 and figure 6. The position trace of the ideal system (i.e. the system without packet drops) is also given in figure 7. The corresponding cost J

for each case is given in the figure comment.

Comparing figure 5 and figure 6 shows that the position trace under the optimal packet delivery sequence is more convergent than that under the arbitrary packet delivery sequence. The comparison of the costs confirms also the improvement in QoC under the optima packet delivery sequence. Figure 7 shows that the state trace of the ideal system shown is slightly more convergent than that in figure 6, and the cost is also a little better. Nevertheless, the request for network bandwidth of the cart system under the (3,11)-firm constraint has decreased significantly. The system requires only 27% of required network bandwidth of the ideal system, reducing thus considerably the network overload.




Figure 5. Position trace of the cart with $f_0=3$, $f_1=1$ and $f_2=7$. $J=15.9487$. (3,11)-firm constraint




Figure 6. Position trace of the cart with $f_0=3$, $f_1=4$ and $f_2=4$. $J=12.2857$. (3,11)-firm constraint




Figure 7. Position trace of the cart without packet drops. $J=10.7041$ (1,1)-firm constraint

6. Conclusion and perspective

This paper consider a overload management technique based on (m,k) -firm constraint that selectively drops the data packets of the NCS to reduce the required network bandwidth. The paper first gives the controller design method based on the (m,k) -firm constraint. Then, it proposes a formal method to derive optimal packet delivery sequence. To reduce the computation complexity, a computationally cheaper algorithm is also proposed.

The results of this paper provide the theoretic basis for the application of (m,k) -firm model in control systems. As a future work, we plan to further extend the proposed approach so that control application can be adapted not only to cope with the overloads, but also to conform to the control application dynamics and the feasibility of the scheduling. That is, to explore an integrated QoC management framework based on (m,k) -firm model that dynamically tunes the (m,k) -constraints of control systems according to changes in the network charge.

References

- [1] Astrom. K.J. and Wittenmark. B. "Computer-Controlled Systems: Theory and Design", 3rd ed. Englewood Cliffs, NJ: Prentice-Hall, 1997.
- [2] Bittanti, S. Bittanti, P. Colaneri, and G. De Nicolao, The periodic Riccati equation, in "The Riccati Equation" (S. Bittanti, A. J. Laub, and J. C. Willems, Eds.), pp. 127-162, Springer-Verlag, Berlin, 1991.
- [3] Cervin. A, Eker. J, Bernhardsson. B, and Årzn. K.-E, "Feedback feedforward scheduling of control tasks," *Real-Time Syst.*, vol. 23, no. 1-2, pp. 25--53, 2002.
- [4] Cervin. J, Eker. J, "Control-Scheduling Codesign of Real-Time Systems: The Control Server Approach". *Journal of Embedded Computing*, 1:2, pp. 209--224, January 2005.
- [5] Eker. J, Hagander. P, and Årzn. K.E, "A Feedback Scheduler for Real-Time Controller Tasks", *Control Engineering Practice*, 12, 8, 2000, p. 1369-1378.
- [6] Felicioni. F, Jia. N, Song. Y.Q, Simonot-Lion. F, "Impact of a (m,k) -firm data dropouts policy on the quality of control", *6th IEEE International Workshop on Factory Communication Systems - WFCS'2006*. (Torino, Italy). 2006.
- [7] Gustafsson. K, and Hagander, P (1991). "Discrete-time LQG with cross-terms in the loss function and the noise description" Report TFRT-7475
- [8] Quan. G, and Hu. X, "Enhanced Fixed-priority Scheduling with (m,k) -firm Guarantee", *Proc. Of*

21st IEEE Real-Time Systems Symposium, pp.79-88, Orlando, Florida, (USA), November 27-30, 2000.

- [9] Jia. N, Song. Y.Q, and LIN. R.Z, "Analysis of networked control system with packet drops governed by (m,k) -firm constraint", *6th IFAC International Conference on Fieldbus Systems and their Applications - FeT'2005*. (Puebla, Mexico). 2005.
- [10] Land A. H. and Doig. A. G., "An Automatic Method for Solving Discrete Programming Problems". *Econometrica*, Vol.28 (1960), pp. 497-520.
- [11] Ling. Q and M.D. Lemmon, "Robust performance of soft real-time networked control systems with data dropouts", *Proc. Of the IEEE Conference on Decision and Control*, 2002.
- [12] Ling. Q. and M.D. Lemmon, "Soft real-time scheduling of networked systems with dropouts governed by a Markov chain", *Proc. Of the American Conference on Control*, 2003.
- [13] Lothaire. M. "Combinatorics on Word". Cambridge Academic Press, second edition, 1997.
- [14] Ramanathan. P, "Overload management in Real-Time control applications using (m,k) -firm guarantee", *IEEE Transactions on Parallel and Distributed Systems*, 10(6) :549-559, Jun 1999.
- [15] Simon. D, Robert. D and Sename. O, "Robust control/scheduling co-design: application to robot control", *RTAS'05 11th IEEE Real-Time and Embedded Technology and Applications Symposium* march 2005 San Francisco, CA
- [16] Zhang. W. M. S. Brannicky, and S. M. Philips, "Stability analysis of networked control systems", *IEEE Control System Magazine*, 21(1):84-89, Feb 2001.

Appendix A – proof of theorem 1

Proof. From (6) and (7), we get

$$\left(\Gamma_i^T S_{i+1} \Gamma_i + R_i'\right) L_i = \left(\Phi_i^T S_{i+1} \Phi_i + M_i^T\right) \quad (17)$$

and

$$S_i + L_i^T \left(\Gamma_i^T S_{i+1} \Gamma_i + R_i'\right) L_i = \left(\Phi_i^T S_{i+1} \Phi_i + Q_i\right)^T \quad (18)$$

Regrouping (17) and (18) into a matrix, we get

$$\begin{bmatrix} S_i + L_i^T G_i L_i & L_i^T G_i \\ G_i L_i & G_i \end{bmatrix} = \begin{bmatrix} \Phi_i^T \\ \Gamma_i^T \end{bmatrix} S_{i+1} [\Phi_i \quad \Gamma_i] + Q_{i,d} \quad (19)$$

where $G_i = \Gamma_i^T S_{i+1} \Gamma_i + R_i'$, and

$$Q_{i,d} = \begin{bmatrix} Q_{i,1d} & Q_{i,2d} \\ Q_{i,2d}^T & Q_{i,3d} \end{bmatrix} = \int_0^{f_i} e^{\Sigma^T t} \begin{bmatrix} Q & 0 \\ 0 & R \end{bmatrix} e^{\Sigma t} dt$$

with

$$e^{\Sigma t} = \exp\left(\begin{bmatrix} A & B \\ 0 & 0 \end{bmatrix} t\right) = \begin{bmatrix} \Phi(t) & \Gamma(t) \\ 0 & I \end{bmatrix}$$

To find out how J depends on the packet delivery sequence, it remains to investigate S . Eq. (19) is differentiated with respect to f_i

$$\begin{aligned} & \begin{bmatrix} 0 & 0 \\ \frac{dL_i}{df_i} & 0 \end{bmatrix}^T \begin{bmatrix} S_i & 0 \\ 0 & G_i \end{bmatrix} \begin{bmatrix} I & 0 \\ L_i & I \end{bmatrix} + \\ & \begin{bmatrix} I & 0 \\ L_i & I \end{bmatrix}^T \begin{bmatrix} \frac{dS_i}{df_i} & 0 \\ 0 & \frac{dG_i}{df_i} \end{bmatrix} \begin{bmatrix} I & 0 \\ L_i & I \end{bmatrix} + \\ & \begin{bmatrix} I & 0 \\ L_i & I \end{bmatrix}^T \begin{bmatrix} S_i & 0 \\ 0 & G_i \end{bmatrix} \begin{bmatrix} 0 & 0 \\ \frac{dL_i}{df_i} & 0 \end{bmatrix} = \\ & \frac{dQ_{i,d}}{df_i} + \begin{bmatrix} \frac{d\Phi_i^T}{df_i} \\ \frac{d\Gamma_i^T}{df_i} \end{bmatrix} S_{i+1} [\Phi_i \quad \Gamma_i] + \begin{bmatrix} \Phi_i^T \\ \Gamma_i^T \end{bmatrix} \frac{dS_{i+1}}{df_i} [\Phi_i \quad \Gamma_i] \\ & + \begin{bmatrix} \Phi_i^T \\ \Gamma_i^T \end{bmatrix} S_{i+1} \begin{bmatrix} \frac{d\Phi_i}{df_i} & \frac{d\Gamma_i}{df_i} \end{bmatrix} \end{aligned}$$

Rearranging the terms yields

$$\begin{aligned} & \begin{bmatrix} 0 & \frac{dL_i^T}{df_i} G \\ 0 & 0 \end{bmatrix} + \begin{bmatrix} \frac{dS_i}{df_i} & 0 \\ 0 & \frac{dG_i}{df_i} \end{bmatrix} + \begin{bmatrix} 0 & 0 \\ G \frac{dL_i}{df_i} & 0 \end{bmatrix} = \\ & \begin{bmatrix} \Phi_i^T - L_i^T \Gamma_i^T \\ \Gamma_i^T \end{bmatrix} \frac{dS_{i+1}}{df_i} [\Phi_i - \Gamma_i L_i \quad \Gamma_i] + \begin{bmatrix} I & 0 \\ -L_i & I \end{bmatrix}^T \bar{W}_i \begin{bmatrix} I & 0 \\ -L_i & I \end{bmatrix} \quad (20) \end{aligned}$$

where

$$\bar{W}_i = \frac{dQ_{i,d}}{df_i} + \begin{bmatrix} \frac{d\Phi_i^T}{df_i} \\ \frac{d\Gamma_i^T}{df_i} \end{bmatrix} S_{i+1} [\Phi_i \quad \Gamma_i] + \begin{bmatrix} \Phi_i^T \\ \Gamma_i^T \end{bmatrix} S_{i+1} \begin{bmatrix} \frac{d\Phi_i}{df_i} & \frac{d\Gamma_i}{df_i} \end{bmatrix}$$

From (20) the following equation is obtained

$$\frac{dS_i}{df_i} = \Psi_i^T \frac{dS_{i+1}}{df_i} \Psi_i + \begin{bmatrix} I & -L_i^T \\ 0 & 0 \end{bmatrix} \bar{W}_i \begin{bmatrix} I \\ -L_i \end{bmatrix}$$

where $\Psi_i = \Phi_i - \Gamma_i L_i$.

By the same approach, we get

$$\frac{dS_j}{df_i} = \Psi_{j+1}^T \frac{dS_{j+1}}{df_i} \Psi_{j+1} \quad \text{for } \text{mod}\left(\frac{j}{m}\right) \neq i$$

To calculate \bar{W}_i , formulas for $\frac{dQ_{i,d}}{df_i}$, $\frac{d\Phi_i}{df_i}$ and $\frac{d\Gamma_i}{df_i}$ are needed:

$$\frac{d\Phi_i}{df_i} = hA\Phi_i \quad \frac{d\Gamma_i}{df_i} = hA\Gamma_i + hB$$

$$\frac{dQ_{i,d}}{df_i} = he^{\sum^r f_i h} \begin{bmatrix} Q & 0 \\ 0 & R \end{bmatrix} e^{\sum^r f_i h} = h \begin{bmatrix} \Phi_i & \Gamma_i \\ 0 & I \end{bmatrix}^T Q_{i,c} \begin{bmatrix} \Phi_i & \Gamma_i \\ 0 & I \end{bmatrix}$$

\bar{W}_i is now written as:

$$\begin{aligned} \bar{W}_i &= h \begin{bmatrix} \Phi_i & \Gamma_i \\ 0 & I \end{bmatrix}^T \begin{bmatrix} Q & 0 \\ 0 & R \end{bmatrix} \begin{bmatrix} \Phi_i & \Gamma_i \\ 0 & I \end{bmatrix} \\ &+ \begin{bmatrix} (hA\Phi_i)^T \\ (hA\Gamma_i + hB)^T \end{bmatrix} S_{i+1} \begin{bmatrix} \Phi_i & \Gamma_i \end{bmatrix} + \begin{bmatrix} \Phi_i^T \\ \Gamma_i^T \end{bmatrix} S_{i+1} [Ah\Phi_i \quad hA\Gamma_i + hB] \end{aligned}$$

Let W be

$$\begin{aligned} W_i &= \begin{bmatrix} I & -L_i^T \\ 0 & -L_i \end{bmatrix} \bar{W}_i \begin{bmatrix} I \\ -L_i \end{bmatrix} = h \begin{bmatrix} \Psi_i^T & -L_i^T \\ 0 & I \end{bmatrix} \begin{bmatrix} \Phi_i & \Gamma_i \\ 0 & I \end{bmatrix} \begin{bmatrix} \Psi_i \\ -L_i \end{bmatrix} \\ &+ (h\Psi_i^T A^T - hL_i^T B^T) S_{i+1} \Psi_i + \Psi_i^T S_{i+1} (hA\Psi_i - hBL_i) \end{aligned}$$

we get therefore

$$\frac{dS_i}{df_i} = \Psi_i^T \frac{dS_{i+1}}{df_i} \Psi_i + W_i$$

and $\frac{dJ}{df_i}$ may be calculated.

□